

Listing and Technical Evaluation Report™

A Duly Authenticated Report from an Approved Agency

Report No: 1911-04



Issue Date: December 22, 2020

Revision Date: August 26, 2026

Subject to Renewal: October 1, 2027

Big Timber® WTX™ Wood Screw Properties

Trade Secret Report Holder:

Western Builders Supply dba Big Timber®

Phone: 406-252-6309

Website: www.marmonfasteners.com/big-timber-us

Email: sales@bigtimberfasteners.com

CSI Designations:

DIVISION: 06 00 00 - WOOD, PLASTICS AND COMPOSITES

Section: 06 05 23 - Wood, Plastic, and Composite Fastenings

1 Innovative Product Evaluated¹

- 1.1 Big Timber WTX Wafer Head Wood Screws

2 Product Description and Materials

- 2.1 WTX Wafer Head Wood Screws have a round wafer head with a star drive (Torx screw) and are partially threaded with a Type 17 tip.
- 2.2 The innovative product evaluated in this report is shown in **Figure 1**.



Figure 1. WTX Wafer Head Wood Screw

- 2.3 WTX Wafer Head Wood Screws are manufactured using a standard cold-formed process, followed by a heat-treating process.
- 2.4 WTX Wafer Head Wood Screws are coated with a proprietary coating, designated as Black.



2.5 WTX Wafer Head Wood Screws, approved for use in chemically treated or untreated lumber where ASTM A153, Class D coatings are approved for use in accordance with IBC Section 2304.10 and IRC Section R304.3.²

2.5.1 The proprietary coating has been tested and found to exceed the protection provided by code-approved hot-dipped galvanized coatings meeting ASTM A153, Class D (IBC Section 2304.10.6³ and IRC Section R304.3⁴), allowing for its use in pressure treated wood.

2.5.2 WTX Wafer Head Wood Screws are approved for use in fire-retardant treated lumber, provided the conditions set forth by the fire retardant-treated lumber manufacturer be met, including appropriate strength reductions.

Table 1. Fastener Specifications

Fastener Name	Designation	Head (in)		Nominal Length ¹ (in)	Thread Length ² (in)	Shank Diameter ³ (in)	Thread Diameter (in)		Specified Min Core Hardness ⁵ (HV 0.3)	Nominal Bending Yield, f _{yb} (psi)	Allowable Fastener Strength (lbf)	
		Diameter	Drive Type				Minor	Major			Tensile	Shear ⁴
WTX	15 x 3"	0.659	Torx 30	3	2 ³ / ₄	0.205	0.187	0.274	286	190,000	1,545	1,165
	15 x 3 ¹ / ₂ "			3 ¹ / ₂	2							
	15 x 4"			4	2							
	15 x 4 ¹ / ₂ "			4 ¹ / ₂	2							
	15 x 5"			5	2							
	15 x 6"			6	1 ¹ / ₂							
	15 x 7"			7	2 ¹ / ₂							
	15 x 8"			8	2 ¹ / ₂							
	15 x 9"			9	2 ¹ / ₂							
	15 x 10"			10	2 ¹ / ₂							
	15 x 11"			11	2 ¹ / ₂							
	15 x 12"			12	2 ¹ / ₂							
	15 x 13"			13	2 ¹ / ₂							
	15 x 14"			14	2 ¹ / ₂							

SI: 1 in = 25.4 mm, 1 lb = 4.45 N, 1-psi = 0.00689 MPa

1. Fastener length is measured from the top of the head to the tip.
2. Thread length excludes the knurl. The WTX 15 x 3" is fully threaded (no knurl).
3. Shank diameter based on manufactured thickness. Finished dimensions are larger due to the added proprietary coatings.
4. Shear determined at thread or smooth shank diameter.
5. Based on a 300-gram load using the Vickers indenter.

2.6 As needed, review material properties for design in **Section 6** and the regulatory evaluation in **Section 8**.



3 Definitions⁵

- 3.1 New Materials⁶ are defined as building materials, equipment, appliances, systems, or methods of construction, not provided for by prescriptive and/or legislatively adopted regulations, known as alternative materials.⁷ The design strength and permissible stresses shall be established by tests⁸ and/or engineering analysis.⁹
- 3.2 Duly authenticated reports¹⁰ and research reports¹¹ are test reports and related engineering evaluations that are written by an approved agency¹² and/or an approved source.¹³
- 3.2.1 This report utilizes intellectual property and/or trade secrets to create public domain material properties for commercial end-use.
- 3.2.1.1 This report protects confidential Intellectual Property and trade secrets under the regulation, 18.U.S.Code.90, also known as Defend Trade Secrets Act of 2016 (DTSA).¹⁴
- 3.3 An approved agency is “approved” when it is ANAB ISO/IEC 17065 accredited. DrJ Engineering, LLC (DrJ) is accredited and listed in the ANAB directory.
- 3.4 An approved source is “approved” when a professional engineer (i.e., Registered Design Professional, hereinafter RDP) is properly licensed to transact engineering commerce. The regulatory authority governing approved sources is the state legislature via its professional engineering regulations.¹⁵
- 3.5 Testing and/or inspections conducted for this duly authenticated report were performed by an ISO/IEC 17025 accredited testing laboratory, an ISO/IEC 17020 accredited inspection body, and/or a licensed RDP.
- 3.5.1 The Center for Building Innovation (CBI) is ANAB¹⁶ ISO/IEC 17025 and ISO/IEC 17020 accredited.
- 3.6 The regulatory authority shall enforce¹⁷ the specific provisions of each legislatively adopted regulation. If there is a non-conformance, the specific regulatory section and language of the non-conformance shall be provided in writing¹⁸ stating the nonconformance and the path to its cure.
- 3.7 The regulatory authority shall accept duly authenticated reports from an approved agency and/or an approved source with respect to the quality and manner of use of new materials or assemblies as provided for in regulations regarding the use of alternative materials, designs, or methods of construction.¹⁹
- 3.8 ANAB is an International Accreditation Forum (IAF) Multilateral Recognition Arrangement (MLA) signatory. Therefore, recognition of certificates and validation statements issued by conformity assessment bodies accredited by all other signatories of the IAF MLA with the appropriate scope shall be approved.²⁰ Thus, all ANAB ISO/IEC 17065 duly authenticated reports are approval equivalent,²¹ and can be used in any country that is an MLA signatory found at this link: <https://iaf.nu/en/recognised-abs/>
- 3.9 Approval equity is a fundamental commercial and legal principle.²²

4 Applicable Local, State, and Federal Approvals; Standards; Regulations²³

4.1 *Local, State, and Federal*

- 4.1.1 Approved in all local jurisdictions pursuant to ISO/IEC 17065 duly authenticated report use, which includes, but is not limited to, the following featured local jurisdictions: Austin, Baltimore, Broward County, Chicago, Clark County, Dade County, Dallas, Detroit, Denver, DuPage County, Fort Worth, Houston, Kansas City, King County, Knoxville, Las Vegas, Los Angeles City, Los Angeles County, Miami, Nashville, New York City, Omaha, Philadelphia, Phoenix, Portland, San Antonio, San Diego, San Jose, San Francisco, Seattle, Sioux Falls, South Holland, St. Louis County, Texas Department of Insurance, and Wichita.²⁴
- 4.1.2 Approved in all state jurisdictions pursuant to ISO/IEC 17065 duly authenticated report use, which includes, but is not limited to, the following featured states: California, Florida, New Jersey, Oregon, New York, Texas, Washington, and Wisconsin.²⁵



4.1.3 Approved by the Code of Federal Regulations Manufactured Home Construction: Pursuant to Title 24, Subtitle B, Chapter XX, Part 3282.14²⁶ and Part 3280²⁷ pursuant to the use of ISO/IEC 17065 duly authenticated reports.

4.1.4 Approved means complying with the requirements of local, state, or federal legislation.

4.2 Regulations

4.2.1 *IBC – 18, 21, 24: International Building Code®*

4.2.2 *IRC – 18, 21, 24: International Residential Code®*

4.2.3 *FBC-B – 20, 23: Florida Building Code²⁸ – Building (FL41095)*

4.2.4 *FBC-R – 20, 23: Florida Building Code²⁸ – Residential (FL41095)*

4.3 Standards

4.3.1 *AISI S904: Standard Test Methods for Determining the Tensile and Shear Strength of Screws*

4.3.2 *ANSI/APA PRS 610.1: Standard for Performance-Rated Structural Insulated Panels in Wall Applications*

4.3.3 *ASTM A153: Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware*

4.3.4 *ASTM A510: Standard Specification for General Requirements for Wire Rods and Coarse Round Wire, Carbon Steel, and Alloy Steel*

4.3.5 *ASTM B117: Standard Practices for Operating Salt Spray (Fog) Apparatus*

4.3.6 *ASTM D1761: Standard Test Methods for Mechanical Fasteners in Wood and Wood-Based Materials*

4.3.7 *ASTM D2395: Standard Test Methods for Density and Specific Gravity (Relative Density) of Wood and Wood-Based Materials*

4.3.8 *ASTM D2915: Standard Practice for Sampling and Data-Analysis for Structural Wood and Wood-Based Products*

4.3.9 *ASTM D4442: Standard Test Methods for Direct Moisture Content Measurement of Wood and Wood-Based Materials*

4.3.10 *ASTM F1575-21: Standard Test Method for Determining Bending Yield Moment of Nails, Spikes, and Dowel-type Threaded Fasteners*

4.3.11 *ASTM G85: Standard Practice for Modified Salt Spray (Fog) Testing*

4.3.12 *DOC PS 2: Performance Standard for Wood-based Structural-use Panels*

5 Listed²⁹

5.1 Equipment, materials, products, or services included in a List published by a nationally recognized testing laboratory (e.g., CBI), an approved agency (e.g., CBI and DrJ), and/or an approved source (e.g., DrJ), or other organization(s) concerned with product evaluation (e.g., DrJ), that maintains periodic inspection (e.g., CBI) of production of listed equipment or materials, and whose listing states either that the equipment or material meets nationally recognized standards or has been tested and found suitable for use in a specified manner.

6 Tabulated Properties Generated from Nationally Recognized Standards

6.1 General

6.1.1 WTX Wafer Head Wood Screws are used to attach wood framing members in conventional light-frame construction and provide resistance against withdrawal, head pull-through, axial, and shear loads. See **Section 9** for installation requirements.

6.1.2 WTX Wafer Head Wood Screws are installed without lead holes, as prescribed in the NDS.

6.1.3 Where the application exceeds the limitations set forth herein, design shall be permitted in accordance with accepted engineering procedures, experience and technical judgment.



6.2 Design

- 6.2.1 Design of WTX Wafer Head Wood Screws is governed by the applicable code and the provisions for dowel-type fasteners in the NDS.
- 6.2.2 Unless otherwise noted, adjustment of the design stresses for duration of load shall be in accordance with the applicable code.

6.3 WTX Reference Lateral Design Values (Z)

- 6.3.1 Reference lateral design values (lbf) for shear load perpendicular to grain and parallel to grain for WTX Wafer Head Wood Screws in sawn lumber, are specified in **Table 2**.

Table 2. WTX Wafer Head Wood Screws Reference Lateral Design Values (Z)
for Connections in Sawn Lumber, lbf^{1,2,3,4}

Fastener Name	Designation	Nominal Length (in)	Thread Length (in)	Minimum Side Member Thickness (in)	Minimum Main Member Penetration ⁵ (in)	Wood Species (Specific Gravity)			
						HF/SPF (0.42)		DF-L (0.50)	
						Z [⊥]	Z	Z [⊥]	Z
WTX	15 x 3"	3	2 ³ / ₄	1 ¹ / ₂	1 ¹ / ₂	280	225	310	280
	15 x 3 ¹ / ₂ "	3 ¹ / ₂	2						
	15 x 4"	4	2						
	15 x 4 ¹ / ₂ "	4 ¹ / ₂	2						
	15 x 5"	5	2						
	15 x 6"	6	2 ¹ / ₂						
	15 x 7"	7	2 ¹ / ₂						
	15 x 8"	8	2 ¹ / ₂						
	15 x 9"	9	2 ¹ / ₂						
	15 x 10"	10	2 ¹ / ₂						
	15 x 11"	11	2 ¹ / ₂						
	15 x 12"	12	2 ¹ / ₂						
	15 x 13"	13	2 ¹ / ₂						
	15 x 14"	14	2 ¹ / ₂						

SI: 1 in = 25.4 mm, 1 lb = 4.45 N, 1 lb/in = 0.175 kN/m

- Reference lateral design values apply to two-member single shear connections where both members are of the same specific gravity and the fastener is oriented perpendicular to grain. Where the members are of different specific gravities, use the lower of the two.
- For wood species with a specific gravity between 0.42 and 0.50, use the tabulated values for specific gravity of 0.42.
- Tabulated lateral design values (Z) shall be adjusted by all applicable adjustment factors per NDS Table 11.3.1.
- Z[⊥] = Lateral Design Values Perpendicular to Grain; Z_{||} = Lateral Design Values Parallel to Grain.
- Fastener main member penetration is the length embedded in the main member, including the tip. When choosing the length of fastener, the thickness of the side member and main member assembly shall be considered so that the fastener does not penetrate through the backside of the main member.



6.3.2 Reference lateral design values (lbf) for Structural Insulation Panels (SIP) are specified in **Table 3**.

Table 3. WTX Wafer Head Wood Screws Reference Lateral Design Values (Z) in SIP, lbf

Fastener Name	Designation	Nominal Length (in)	Thread Length (in)	SIP Total Thickness ^{1,2,3} (in)	Main Member Wood Species ^{4,5} (Specific Gravity)	Lateral Design Value, ⁶ Z (lbf)
WTX	15 x 5"	5	2	3½	HF/SPF (0.42)	270
	15 x 8"	8	2½	6½		270
	15 x 5"	5	2	3½	DF-L (0.50)	290
	15 x 8"	8	2½	6½		290

SI: 1 in = 25.4 mm, 1 lb = 4.45 N, 1 lb/in = 0.175 kN/m

- SIP thickness is measured from exterior face to exterior face. Each SIP consists of two 7/16" OSB faces with a foam core in between.
- The OSB faces on the SIP shall comply with ANSI/APA PRS 610.1.
- Fastener shall be driven so that the underside of the head is flush with the face of the SIP.
- For main member wood species with a specific gravity between 0.42 and 0.50, use the tabulated values for specific gravity of 0.42.
- The fastener is driven into the face of the main member and is loaded parallel to the grain.
- Tabulated lateral design values (Z) shall be adjusted by all applicable adjustment factors per [NDS Table 11.3.1](#).

6.4 WTX Reference Withdrawal Design Values (W) in Side Grain Applications

6.4.1 Reference withdrawal design values (lbf/in) for WTX Wafer Head Wood Screws are specified in **Table 4**.

Table 4. WTX Wafer Head Wood Screws Reference Withdrawal Values (W) – Side Grain applications, lbf/in

Fastener Name	Designation	Nominal Length (in)	Thread Length (in)	Withdrawal Design Value, ^{1,2,4} W (lbf/in)	
				Wood Species ³ (Specific Gravity)	
				HF/SPF (0.42)	DF-L (0.50)
WTX	15 x 3"	3	2¾	230	240
	15 x 3½"	3½	2		
	15 x 4"	4	2		
	15 x 4½"	4½	2		
	15 x 5"	5	2		
	15 x 6"	6	2½		
	15 x 7"	7	2½		
	15 x 8"	8	2½		
	15 x 9"	9	2½		
	15 x 10"	10	2½		
	15 x 11"	11	2½		
	15 x 12"	12	2½		
	15 x 13"	13	2½		
	15 x 14"	14	2½		

SI: 1 in = 25.4 mm, 1 lb = 4.45 N, 1 lb/in = 0.175 kN/m

- Tabulated withdrawal values (W) shall be adjusted by all applicable adjustment factors per [NDS Table 11.3.1](#).
- Minimum fastener penetration into main member of 1" is required. Fastener penetration is the threaded length embedded in the main member, including the tip.
- For wood species with a specific gravity between 0.42 and 0.50, use the tabulated values for specific gravity of 0.42.
- The full design withdrawal value is equal to the reference withdrawal value, multiplied by the length of the threaded portion of the fastener embedded in the main member.



6.5 WTX Reference Head Pull-Through Design Values (P)

6.5.1 Reference design values for head pull-through (lbf) for WTX Wafer Head Wood Screws are as specified in **Table 5**.

Table 5. WTX Wafer Head Wood Screws Reference Head Pull-Through Design Values (P), lbf

Fastener Name	Designation	Nominal Length (in)	Thread Length (in)	Head Pull-Through Design Value, ¹ P (lbf)		
				OSB Grade and Assembly		
				⁷ / ₁₆ " OSB ²	⁷ / ₁₆ " OSB SIP Face Material ³	⁷ / ₁₆ "OSB SIP Face Material ³ with Metal Washer ⁴
WTX	15 x 3"	3	2 ³ / ₄	210	245	390
	15 x 3 ¹ / ₂ "	3 ¹ / ₂	2			
	15 x 4"	4	2			
	15 x 4 ¹ / ₂ "	4 ¹ / ₂	2			
	15 x 5"	5	2			
	15 x 6"	6	2 ¹ / ₂			
	15 x 7"	7	2 ¹ / ₂			
	15 x 8"	8	2 ¹ / ₂			
	15 x 9"	9	2 ¹ / ₂			
	15 x 10"	10	2 ¹ / ₂			
	15 x 11"	11	2 ¹ / ₂			
	15 x 12"	12	2 ¹ / ₂			
	15 x 13"	13	2 ¹ / ₂			
	15 x 14"	14	2 ¹ / ₂			

SI: 1 in = 25.4 mm, 1 lb = 4.45 N, 1 lb/in = 0.175 kN/m

- Tabulated pull-through values (P) shall be adjusted by all applicable adjustment factors per [NDS Table 11.3.1](#).
- OSB shall comply with DOC PS 2 and shall have a specific gravity of at least 0.50.
- The OSB faces on the SIP shall comply with ANSI/APA PRS 610.1.
- The fastener shall be installed with a minimum 2" diameter, 20-gauge metal washer between the fastener head and the face of the OSB.

6.6 Alternative techniques shall be permitted in accordance with accepted engineering practice and experience. These provisions for the use of alternative materials, designs, and methods of construction are not intended to prevent the installation of any material or to prohibit any design or method of construction not specifically prescribed herein. This includes, but is not limited to, the following areas of engineering: mechanics of materials, structures, building science, and fire science.



7 Certified Performance³⁰

- 7.1 All construction methods shall conform to accepted engineering practices to ensure durable, livable, and safe construction and shall demonstrate acceptable workmanship reflecting journeyman quality of work of the various trades.³¹
- 7.2 The strength and rigidity of the component parts and/or the integrated structure shall be determined by engineering analysis or by suitable load tests to simulate the actual loads and conditions of application that occur.³²

8 Regulatory Evaluation and Accepted Engineering Practice

- 8.1 WTX Wafer Head Wood Screws comply with the following legislatively adopted regulations and/or accepted engineering practice for the following reasons:
 - 8.1.1 Bending yield in accordance with ASTM F1575
 - 8.1.2 Tensile strength in accordance with AISI S904
 - 8.1.3 Shear strength in accordance with AISI S904
 - 8.1.4 Lateral shear in accordance with ASTM D1761
 - 8.1.5 Withdrawal strength in accordance with ASTM D1761
 - 8.1.6 Head pull-through in accordance with ASTM D1761
 - 8.1.7 Corrosion resistance in accordance with ASTM B117 and ASTM G85
- 8.2 Any building code, regulation and/or accepted engineering evaluations (e.g., research reports, duly authenticated reports, etc.) that are conducted for this Listing were performed by DrJ, which is an ISO/IEC 17065 accredited certification body and a professional engineering company operated by RDP or approved sources. DrJ is qualified³³ to practice product and regulatory compliance services within its scope of accreditation and engineering expertise,³⁴ respectively.
- 8.3 Engineering evaluations are conducted with DrJ's ANAB accredited ICS code scope of expertise, which is also its areas of professional engineering competence.

9 Installation

- 9.1 Installation shall comply with the approved construction documents, the manufacturer installation instructions, this report, and the applicable building code.
- 9.2 In the event of a conflict between the manufacturer installation instructions and this report, contact the manufacturer for counsel on the proper installation method.
- 9.3 *Installation Procedure*
 - 9.3.1 Minimum penetration is 1", unless otherwise stated in this report.
 - 9.3.2 Install fasteners with the underside of the head flush to the surface of the wood member.
 - 9.3.3 Lead holes are not required.
 - 9.3.4 Screws shall be installed with the appropriate rotating powered driver.
 - 9.3.5 Minimum requirements for screw spacing, edge distance, and end distance shall be in accordance with **Table 6**.



Table 6. WTX 15 Screw Spacing, Edge Distance, and End Distance Requirements¹

Connection Geometry	Minimum Spacing/Distance (in)
Edge Distance – Load in any direction	$\frac{5}{8}$
End Distance – Load parallel to grain, towards end	$3\frac{1}{8}$
End Distance – Load parallel to grain, away from end	$2\frac{1}{8}$
End Distance – Load perpendicular to grain	$2\frac{1}{8}$
Spacing between Fasteners in a Row – Parallel to grain	$3\frac{1}{8}$
Spacing between Fasteners in a Row – Perpendicular to grain	$2\frac{1}{8}$
Spacing between Rows of Fasteners – In-line	$1\frac{1}{8}$
Spacing between Rows of Fasteners – Staggered ²	$\frac{5}{8}$

SI: 1 in = 25.4 mm

- Edge distances, end distances, and spacing of fasteners shall be sufficient to prevent splitting of the wood or as shown in this table, whichever is more restrictive.
- Values for “Spacing between Rows of Fasteners-Staggered” apply where the screws in adjacent rows are offset by one-half of the “Spacing between Fasteners in a Row”.

10 Substantiating Data

10.1 Testing has been performed under the supervision of a professional engineer and/or under the requirements of ISO/IEC 17025 as follows:

- 10.1.1 Bending yield in accordance with ASTM F1575
- 10.1.2 Tensile strength in accordance with AISI S904
- 10.1.3 Shear strength in accordance with AISI S904
- 10.1.4 Lateral shear in accordance with ASTM D1761
- 10.1.5 Withdrawal strength in accordance with ASTM D1761
- 10.1.6 Head pull-through in accordance with ASTM D1761
- 10.1.7 Corrosion resistance in accordance with ASTM B117 and ASTM G85

10.2 Information contained herein may include the result of testing and/or data analysis by sources that are approved agencies, approved sources, and/or an RDP. Accuracy of external test data and resulting analysis is relied upon.

10.3 Where applicable, testing and/or engineering analysis are based upon provisions that have been codified into law through state or local adoption of regulations and standards. The developers of these regulations and standards are responsible for the reliability of published content. DrJ’s engineering practice may use a regulation-adopted provision as the control. A regulation-endorsed control versus a simulation of the conditions of application to occur establishes a new material as being equivalent to the regulatory provision in terms of quality, strength, effectiveness, fire resistance, durability, and safety.

10.4 The accuracy of the provisions provided herein may be reliant upon the published properties of raw materials, which are defined by the grade mark, grade stamp, mill certificate, or duly authenticated reports from approved agencies and/or approved sources provided by the supplier. These are presumed to be minimum properties and relied upon to be accurate. The reliability of DrJ’s engineering practice, as contained in this duly authenticated report, may be dependent upon published design properties by others.



10.5 Testing and Engineering Analysis

- 10.5.1 The strength, rigidity, and/or general performance of component parts and/or the integrated structure are determined by suitable tests that simulate the actual conditions of application that occur and/or by accepted engineering practice and experience.³⁵
- 10.6 Where additional condition of use and/or regulatory compliance information is required, please search for WTX Wafer Head Wood Screws on the [DrJ Certification website](#).

11 Findings

- 11.1 As outlined in **Section 6**, WTX Wafer Head Wood Screws have performance characteristics that were tested and/or meet applicable regulations. In addition, they are suitable for use pursuant to its specified purpose.
- 11.2 When used and installed in accordance with this [duly authenticated report](#) and the manufacturer installation instructions, WTX Wafer Head Wood Screws shall be approved for the following applications:
 - 11.2.1 Use as fasteners in accordance with reference design value properties defined herein, and are approved for use in accordance with the applicable code.
- 11.3 Unless exempt by state statute, when WTX Wafer Head Wood Screws are to be used as a structural and/or building envelope component in the design of a specific building, the design shall be performed by an [RDP](#).
- 11.4 Any application specific issues not addressed herein can be engineered by an [RDP](#). Assistance with engineering is available from Big Timber or Western Builders Supply.
- 11.5 [IBC Section 104.2.3](#)³⁶ ([IRC Section R104.2.2](#)³⁷ and [IFC Section 104.2.3](#)³⁸ are similar) in pertinent part state:

104.2.3 Alternative Materials, Design and Methods of Construction and Equipment. The provisions of this code are not intended to prevent the installation of any material or to prohibit any design or method of construction not specifically prescribed by this code, provided that any such alternative is not specifically prohibited by this code and has been approved.
- 11.6 **Approved:**³⁹ Building regulations require that the [building official](#) shall accept [duly authenticated reports](#).⁴⁰
 - 11.6.1 An [approved agency](#) is “*approved*” when it is [ANAB ISO/IEC 17065 accredited](#).
 - 11.6.2 An [approved source](#) is “*approved*” when an [RDP](#) is properly licensed to transact engineering commerce.
 - 11.6.3 Federal law, [Title 18 US Code Section 242](#), requires that, where the alternative product, material, service, design, assembly, and/or method of construction is not approved, the building official shall respond in writing, stating the reasons why the alternative was not approved. Denial without written reason deprives a protected right to free and fair competition in the marketplace.
- 11.7 DrJ is a licensed engineering company, employs licensed [RDPs](#) and is an [ANAB Accredited Product Certification Body – Accreditation #1131](#).
- 11.8 Through the [IAF Multilateral Arrangement](#) (MLA), this [duly authenticated report](#) can be used to obtain product approval in any [jurisdiction](#) or [country](#) because all ANAB ISO/IEC 17065 [duly authenticated reports](#) are equivalent.⁴¹

12 Conditions of Use

- 12.1 As defined in **Section 6**, where material and/or engineering mechanics properties are created for load resisting design purposes, the resistance to the applied load shall not exceed the ability of the defined properties to resist those loads using the principles of accepted engineering practice.
- 12.2 As listed herein, WTX Wafer Head Wood Screws shall be used:
 - 12.2.1 In sawn lumber with moisture content less than or equal to nineteen percent (19%) or in OSB with moisture content less than or equal to sixteen percent (16%).



- 12.3 Use of fasteners in locations exposed to saltwater or saltwater spray is outside the scope of this report.
- 12.4 When required by adopted legislation and enforced by the building official, also known as the Authority Having Jurisdiction (AHJ) in which the project is to be constructed:
- 12.4.1 Any calculations incorporated into the construction documents shall conform to accepted engineering practice and, when prepared by an approved source, shall be approved when signed and sealed.
 - 12.4.2 This report and the installation instructions shall be submitted at the time of permit application.
 - 12.4.3 At a minimum, this innovative product shall be installed per **Section 9**.
 - 12.4.4 The review of this report by the AHJ shall comply with IBC Section 104.2.3.2 and IBC Section 105.3.1.
 - 12.4.5 This innovative product has an internal quality control program and a third party quality assurance program in accordance with IBC Section 104.7.2, IBC Section 110.4, IBC Section 1703, IRC Section R104.7.2, and IRC Section R109.2.
 - 12.4.6 The application of this innovative product in the context of this report is dependent upon the accuracy of the construction documents, implementation of installation instructions, inspection as required by IBC Section 110.3, IRC Section R109.2, and any other regulatory requirements that may apply.
- 12.5 The approval of this report by the AHJ shall comply with IBC Section 1707.1, where legislation states in part, *"the building official shall make, or cause to be made, the necessary tests and investigations; or the building official shall accept duly authenticated reports from approved agencies in respect to the quality and manner of use of new materials or assemblies as provided for in Section 104.2.3", all of IBC Section 104, and IBC Section 105.3.*
- 12.6 Design loads shall be determined in accordance with the regulations adopted by the jurisdiction in which the project is to be constructed and/or by the building designer (i.e., owner or RDP).
- 12.7 The actual design, suitability, and use of this report for any particular building, is the responsibility of the owner or the authorized agent of the owner.

13 Identification

- 13.1 WTX Wafer Head Wood Screws, as listed in **Section 1.1**, are identified by a label on the board or packaging material bearing the manufacturer name, product name, this report number, and other information to confirm code compliance.
- 13.2 Additional technical information can be found at www.marmonfasteners.com/big-timber-us/product/wtx.

14 Review Schedule

- 14.1 This report is subject to periodic review and revision. For the latest version, visit www.drjcertification.org.
- 14.2 For information on the status of this report, please contact [DrJ Certification](http://www.drjcertification.org).



Issue Date: March 9, 2022

Supplement Revision Date: July 18, 2025

Subject to Renewal: October 1, 2027

FBC Supplement to Report Number 1911-04

REPORT HOLDER: Western Builders Supply dba Big Timber

1 Evaluation Subject

- 1.1 WTX Wafer Head Wood Screws

2 Purpose and Scope

2.1 Purpose

- 2.1.1 The purpose of this Report Supplement is to show WTX Wafer Head Wood Screws, recognized in Report Number 1911-04, have also been evaluated for compliance with the codes listed below as adopted by the Florida Building Commission.

2.2 Applicable Code Editions

- 2.2.1 *FBC-B—20, 23: Florida Building Code – Building (FL41095)*
- 2.2.2 *FBC-R—20, 23: Florida Building Code – Residential (FL41095)*

3 Conclusions

- 3.1 WTX Wafer Head Wood Screws, described in Report Number 1911-04, comply with the FBC-B and FBC-R and are subject to the conditions of use described in this supplement.
- 3.2 Where there are variations between the IBC and IRC and the FBC-B and FBC-R applicable to this report, they are listed here:
 - 3.2.1 FBC-B Section 104 is reserved.
 - 3.2.2 FBC-B Section 110.4 is reserved and replaces IBC Section 110.4.
 - 3.2.3 FBC-B Section 104.6 is reserved and replaces IBC Section 104.4.
 - 3.2.4 FBC-B Section 104.11 replaces IBC Section 104.2.3 and Section 104.2.3.2.
 - 3.2.5 FBC-B Section 105.3 replaces IBC Section 105.3.
 - 3.2.6 FBC-B Section 105.3.1 replaces IBC Section 105.3.1.
 - 3.2.7 FBC-B Section 110.3 replaces IBC Section 110.3.
 - 3.2.8 FBC-B Section 1707.1 replaces IBC Section 1707.1.
 - 3.2.9 FBC-B Section 2304.10 replaces IBC Section 2304.10.
 - 3.2.10 FBC-B Section 2304.10.5 replaces IBC Section 2304.10.6.
 - 3.2.11 FBC-B Section 2306.1 replaces IBC Section 2306.1.
 - 3.2.12 FBC-B Section 2306.3 replaces IBC Section 2306.3.
 - 3.2.13 FBC-R Section R104 and Section R109 are reserved.
 - 3.2.14 FBC-R Section R317.3 replaces IRC Section R304.3.



4 Conditions of Use

4.1 WTX Wafer Head Wood Screws, described in Report Number 1911-04, must comply with all of the following conditions:

- 4.1.1 All applicable sections in Report Number 1911-04.
- 4.1.2 The design, installation, and inspections are in accordance with additional requirements of FBC-B Chapter 16 and Chapter 17, as applicable.



Notes

For more information, visit drjcertification.org or call us at 608-310-6748.

[2021 IRC Section R317.3](#)

[2018 IBC Section 2304.10.5](#)

[2021 IRC Section R317.3](#)

Capitalized terms and responsibilities are defined pursuant to the applicable building code, applicable reference standards, the latest edition of [TPI 1](#), the [NDS](#), [AISI S202](#), [US professional engineering law](#), [Canadian building code](#), [Canada professional engineering law](#), [Qualtim External Appendix A: Definitions/Commentary](#), [Qualtim External Appendix B: Project/Deliverables](#), [Qualtim External Appendix C: Intellectual Property and Trade Secrets](#), definitions created within Design Drawings and/or definitions within Reference Sheets. Beyond this, terms not defined shall have ordinarily accepted meanings as the context implies. Words used in the present tense include the future; words stated in the masculine gender include the feminine and neuter; the singular number includes the plural and the plural, the singular.

<https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1702>

Alternative Materials, Design and Methods of Construction and Equipment: The provisions of any regulation code are not intended to prevent the installation of any material or to prohibit any design or method of construction not specifically prescribed by a regulation. Please review <https://www.justice.gov/atr/mission> and <https://up.codes/viewer/mississippi/ibc-2024/chapter/1/scope-and-administration#104.2.3>

<https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1706.2>:-:text=the%20design%20strengths%20and%20permissible%20stresses%20shall%20be%20established%20by%20tests

The [design strengths](#) and permissible stresses of any structural material shall conform to the specifications and methods of design of accepted engineering practice.

<https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1706.1>:-:text=Conformance%20to%20Standards-.The%20design%20strengths%20and%20permissible%20stresses.-of%20any%20structural

<https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1707.1>:-:text=the%20building%20official%20shall%20make%20a%20cause%20to%20be%20made%20a%20necessary%20tests%20and%20investigations%20or%20the%20building%20official%20shall%20accept%20duly%20authenticated%20reports%20from%20approved%20agencies%20in%20respect%20to%20the%20quality%20and%20manner%20of%20use%20of%20new%20materials%20or%20assemblies%20as%20provided%20for%20in%20Section%20104.2.3.

<https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1703.4.2>

https://up.codes/viewer/mississippi/ibc-2024/chapter/2/definitions#approved_agency

https://up.codes/viewer/mississippi/ibc-2024/chapter/2/definitions#approved_source

<https://www.law.cornell.edu/uscode/text/18/1832> (b) Any organization that commits any offense described in subsection (a) shall be fined not more than the greater of \$5,000,000 or 3 times the value of the stolen trade secret to the organization, including expenses for research and design and other costs of reproducing the trade secret that the organization has thereby avoided. The [federal government](#) and each state have a [public records act](#). To follow DTSA and comply state public records and trade secret legislation requires approval through ANAB ISO/IEC 17065 accredited certification bodies or approved sources. For more information, please review this website: [Intellectual Property and Trade Secrets](#).

<https://www.nspe.org/resources/issues-and-advocacy/professional-policies-and-position-statements/regulation-professional> AND <https://apassociation.org/list-of-engineering-boards-in-each-state-archive/>

<https://www.cbiteest.com/accreditation/>

<https://up.codes/viewer/mississippi/ibc-2024/chapter/1/scope-and-administration#104.1>:-:text=directed%20to%20enforce%20the%20provisions%20of%20this%20code

<https://up.codes/viewer/mississippi/ibc-2024/chapter/1/scope-and-administration#104.2.3> AND <https://up.codes/viewer/mississippi/ibc-2024/chapter/1/scope-and-administration#105.3.1>

<https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1707.1>

<https://iaf.nu/en/about-iaf>

[mla/#](https://iaf.nu/en/about-iaf):-:text=Once%20an%20accreditation%20body%20is%20a%20signatory%20of%20the%20IAF%20MLA%20it%20is%20required%20to%20recognise%20certificates%20and%20validation%20and%20verification%20statements%20issued%20by%20conformity%20assessment%20bodies%20accredited%20by%20all%20other%20signatories%20of%20the%20IAF%20MLA%20C%20with%20the%20appropriate%20scope

True for all ANAB accredited product evaluation agencies and all International Trade Agreements.

<https://www.justice.gov/crt/deprivation-rights-under-color-law> AND <https://www.justice.gov/atr/mission>

Unless otherwise noted, the links referenced herein use un-amended versions of the [2024 International Code Council \(ICC\)](#) 2024 International Code Council (ICC) model codes as foundation references. Mississippi versions of the [IBC 2024](#) and the [IRC 2024](#) are un-amended. This material, product, design, service and/or method of construction also complies with the 2000-2012 versions of the referenced codes and the standards referenced therein. As pertinent to this technical and code compliance evaluation, CBI and/or DrJ staff have reviewed any state or local regulatory amendments to assure this report is in compliance.

See [Adoptions by Publisher](#) for the latest adoption of a non-amended or amended model code by the local jurisdiction. <https://up.codes/codes/general>

See [Adoptions by Publisher](#) for the latest adoption of a non-amended or amended model code by state. <https://up.codes/codes/general>

<https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3282/subpart-A/section-3282.14>

<https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280>

All references to the FBC-B and FBC-R are the same as the 2024 IBC and 2024 IRC unless otherwise noted in the Florida Supplement at the end of this report.

<https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#p-3280.2>(Listed%20or%20certified); <https://up.codes/viewer/mississippi/ibc-2024/chapter/2/definitions#listed> AND <https://up.codes/viewer/mississippi/ibc-2024/chapter/2/definitions#labeled>

<https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1703.4>

<https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#p-3280.2>

3280#:-:text=All%20construction%20methods%20shall%20be%20in%20conformance%20with%20accepted%20engineering%20practices%20to%20insure%20durable%20livable%20and%20safe%20housing%20and%20shall%20demonstrate%20acceptable%20workmanship%20reflecting%20journeyman%20quality%20of%20work%20of%20the%20various%20trades



- 32 <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#:~:text=The%20strength%20and%20rigidity%20of%20the%20component%20parts%20and/or%20the%20integrated%20structure%20shall%20be%20determined%20by%20engineering%20analysis%20or%20by%20suitable%20load%20tests%20to%20simulate%20the%20actual%20loads%20and%20conditions%20of%20application%20that%20occur>
- 33 Qualification is performed by a legislatively defined Accreditation Body. ANSI National Accreditation Board (ANAB) is the largest independent accreditation body in North America and provides services in more than 75 countries. DrJ is an ANAB accredited product certification body.
- 34 <https://anabpd.ansi.org/Accreditation/product-certification/AllDirectoryDetails?prgID=1&orgID=2125&statusID=4#:~:text=Bill%20Payment%20Date-,Accredited%20Scopes,-13%20ENVIRONMENT.%20HEALTH>
- 35 See Code of Federal Regulations (CFR) Title 24 Subtitle B Chapter XX Part 3280 for definition: <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280>
- 36 2021 IBC Section 104.11
- 37 2021 IRC Section R104.11
- 38 2018: <https://up.codes/viewer/wyoming/ifc-2018/chapter/1/scope-and-administration#104.9> AND 2021: <https://up.codes/viewer/wyoming/ibc-2021/chapter/1/scope-and-administration#104.11>
- 39 Approved is an adjective that modifies the noun after it. For example, Approved Agency means that the Agency is accepted officially as being suitable in a particular situation. This example conforms to IBC/IRC/IFC Section 201.4 (<https://up.codes/viewer/mississippi/ibc-2024/chapter/2/definitions#201.4>) where the building code authorizes sentences to have an ordinarily accepted meaning such as the context implies.
- 40 <https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1707.1>
- 41 Multilateral approval is true for all ANAB accredited product evaluation agencies and all International Trade Agreements.